



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	4175-2423:0001
CATEGORY:	4175 - ROOF COVERING (MISCELLANEOUS)
LISTEE:	Eagle Roofing Products 2352 North Locust Avenue, Rialto, CA, 92377 Contact: Sindar, Annette 8004003245 Email: annettes@eagleroofting.com
DESIGN:	Eagle Roofing Products - Concrete Roof Tiles, in profiles: Malibu, Capistrano, or Bel Air. Class A: Deck: 15/32-inch-thick AC grade, Group 1 exterior plywood Incline: 5:12 Underlayment: Tarco® 30lbs underlayment Roof Covering: Eagle Roofing Malibu, Eagle Roofing Capistrano, or Eagle Roofing Bel Air flat roof tiles. Refer to listee's data sheet for detailed product description and operational considerations.
RATING:	ASTM E108 Class A Roof Covering
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, product name, rating, and Intertek label.
APPROVAL:	Refer to listee's Installation Instruction Manual for details. Model complies with the applicable requirements in ASTM E108 to be listed as a Class A roof covering assembly as described under "Design".
NOTES:	

12-15-25 MH



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 12/18/2025

Listing Expires: 06/30/2026

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division